



Installation Clearances

1. This appliance should be installed on non combustible flooring.
2. Recommended minimum service clearance is as follows:

Left, right and rear sides: 24"
 Front : as specified.
 Top height: 24" from top of boiler.

SCALE: NTS	Gasmaster Industries, A Division of Steels Industrial Products Ltd.
DATE: Jun 01, 09	Bldg 8, 15050 54a Avenue, Surrey, B.C. CANADA
DRAWN: Ho	Service Clearance Dual Boilers (4M, 8M)
CHK: HD	
APPROVED: BS	
SHEET: 1/1	
Dim. : Inch	